

DECLARATION OF PERFORMANCE

According to CPR (EU) No.305/2011

Document No. 02-2026

1.	Unique identification code of the product-type	ESCO DCR30A
2.	Type, batch or serial number or any other element allowing identification of the construction product	Batch or serial number: See print on the product Brand: EnormPA
3.	Intended use/s of the construction product as foreseen by the manufacturer	Fire detection and fire alarm systems Power supply equipment Battery Charger Unit / DCR30A 100V-240V AC 50-60Hz Input 48V DC Output 2X 48V DC-20A 2X24V DC-3A
4.	Name and address of the manufacturer	Mikafon Elektronik İnş.San.Ltd.Şti. Şair ziya paşa str, No:8 Beyoğlu/İstanbul (head office) Post code 34420 Keten str No:11 Çayırova/Kocaeli (manufacturing facility) Post code 41420 Phone: +90 212 244 51 77 (pbx) Fax: +90 212 244 51 75 Email: info@mikafon.com.tr
5.	Authorised representative	Not applicable
6.	System or systems of assessment and verification of constancy of performance (AVCP)	System-1
7.	Harmonised standard and notified body	Standard: EN 54-4:1997, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006, EN 54-4:1997/AC:1999 Dedal Attestation & Certification Ltd, Notified body number 1922 Certificate No. 1922-CPR-2078
8.	Address of the notified body/ies	Bulgaria, 8000 Burgas, 54 Macedonia Str.

9. Declared Performance

Essential characteristics	Performance	Harmonised technical specification EN 54-4:1997+A1+A2+AC
Performance of power supply		
- General requirements	Pass	4
- Functions	Pass	5
- Materials, design and manufacture	Pass	6
Operational reliability		
- General requirements	Pass	4
- Functions	Pass	5
- Materials, design and manufacture	Pass	6
- Documentation	Pass	7
- Marking	Pass	8
Durability of operational reliability: temperature resistance		
- Cold (operational)	Pass	9.5
Durability of operational reliability: vibration resistance		

- Impact (operational)	Pass	9.7
- Vibration, sinusoidal (operational)	Pass	9.8
- Vibration, sinusoidal (endurance)	Pass	9.15
<i>Durability of operational reliability: electrical stability</i>		
- Electromagnetic Compatibility (EMC), Immunity tests (operational)	Pass	9.9-9.13
<i>Durability of operational reliability: humidity resistance</i>		
- Damp heat, steady state (operational)	Pass	9.6
- Damp heat, steady state (endurance)	Pass	9.14

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued in accordance with regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by

Ercan Polat / General Manager

Location and date of issue: Çayirova / Kocaeli, 21.08.2026